



1.0 NTU

NANO-RW

	Membrane Lientent	MANO DII
Performance	MgSO ₄ Permeate Flow (Nominal): MgSO ₄ Rejection (Nominal):	11,000 gpd (41.6 m ³ /d) 99.7% (99.5% minimum)
Туре	Configuration: Membrane Polymer: Nominal Membrane Area: Feed/Brine Spacer Thickness:	Spiral Wound Composite Polyamide 400 ft ² (37 m ²) 34 mil (0.87 mm) with HYDRAblock TM Technology
Application Data*	Maximum Applied Pressure: Maximum Chlorine Concentration: Maximum Operating Temperature: pH Range, Operation (Cleaning):	600 psig (4.14 MPa) < 0.1 PPM 113 °F (45 °C) 3.0 - 9.0 (1.0 – 11.5)

Membrane Flement

Maximum Feedwater SDI (15 mins):

Maximum Feed Flow:

Minimum Ratio of Concentrate to

Permeate Flow for any Element:

Maximum Pressure Drop for Each Element:

5.0

75 GPM (17.0 m³/h)

5:1


10 psi

Test Conditions

The stated performance is based on the following test conditions:

2000 ppm MgSO₄ 130 psi (0.9 MPa) Applied Pressure 77 °F (25 °C) Operating Temperature 15% Permeate Recovery 6.5 – 7.0 Feed pH

Maximum Feedwater Turbidity:



A, inches (mm)	B, inches (mm)	C, inches (mm)	Weight, lbs. (kg)
40.0 (1016)	7.89 (200)	1.125 (28.6)	36 (16.4)

Notice:

Permeate flow for individual elements may vary + or - 20 percent. Element weight may vary. All membrane elements are supplied with a brine seal, interconnector, and o-rings. All membrane elements are supplied with a brine seal, interconnector, and o-rings. Elements are enclosed in a sealed polyethylene bag containing deionized water, and then packaged in a cardboard box.

Hydranautics believes the information and data contained herein to be accurate and useful. The information and data are offered in good faith, but without guarantee, as conditions and methods of use of our products are beyond our control. Hydranautics assumes no liability for results obtained or damages incurred through the application of the presented information and data. It is the user's responsibility to determine the appropriateness of Hydranautics' products for the user's responsibility to determine the appropriateness of Hydranautics' products for the user's responsibility to determine the appropriateness of Hydranautics' products for the user's responsibility to determine the appropriateness of Hydranautics' products for the

Hydranautics Corporate: 401 Jones Road, Oceanside, CA 92058 1-800-CPA-PURE Phone: 760-901-2500 Fax: 760-901-2578 info@Hydranautics.com

^{*} The limitations shown here are for general use. For specific projects, operating at more conservative values may ensure the best performance and longest life of the membranes. See Hydranautics Technical Bulletins for more detail on operation limits, cleaning pH, and cleaning temperatures.